

# Emission Test Certificate

Thursday, November 17<sup>th</sup> 2016

Supplier: Matilda Veneer Pty Ltd (18-22 Activity Crescent, Molendinar, QLD, 4214)

Sample Description: Hoop Pine Plywood 30mm

Date Tested: November 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p><b>Green Building Council of Australia</b> <i>Green Star Interiors V1.1 - 12.1.2B</i> <i>Green Star Design &amp; As Built V1.1 - 13.1.2B</i></p>	<p><b>Hoop Pine Plywood 30mm</b></p>
<p>Total Volatile Organic Compound Emission Rate limit: &lt;0.5 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.169 mg/m<sup>2</sup>/hr*</p>

*\*The above results may considered representative of the equivalent and lesser weighted product specifications that are made from the same raw materials and these include Hoop Pine Plywood in the thickness ranges of: 1.5mm, 4.0mm; 6.5mm; 9.5mm; 12.5mm; 16mm; 18.5mm, and 25mm as advised by Matilda Veneer.*



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BEng (Chemical Engineer)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

**CV161101b**