

Test sponsor	Certificate number	Certificate issue date	Certificate expiry date
Matilda Veneer Pty Ltd 18-22 Activity Crescent Molendinar Queensland – 4214 Australia.	FAS200287 SFC1.1	6 October 2020	31 October 2025

Description of assessed product

This certificate documents the findings of the assessment undertaken to determine the likely fire hazard properties of Matilda Lite Ply if tested in accordance with AS/NZS 3837:1998 and assessed in accordance with AS 5637.1:2015.

Assessed product performance

The element of construction described above was assessed by this laboratory on behalf of the test sponsor in accordance with the stated test standard in Table 1 and achieved the results outlined in Table 2. A Complete description of the assessed product can be found within the referenced assessment report.

Table 1 Test standard and assessment report details

Referenced report	Test standard	Referenced report issue date	Referenced report expiry date
FAS200287 R1.1	AS 3837:1998 and AS 5637.1:2015	6 October 2020	31 October 2025

Table 2 Formal assessment summary

Product	Reference test	Variation	Group number	ASEA
Matilda Lite Ply	RTF200232	Thickness greater than 9 mm	Group 3	< 250 m ² /kg

Conditions / validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- The RIR (regulatory information report) or the main assessment report must be provided for regulatory requirements and evidence of compliance.
- Reference should be made to the relevant assessment report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of the assessment report may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia are subject to and conducted in accordance with our standard terms and conditions. These are available on request or at <https://www.element.com/terms/terms-and-conditions>.

Testing authority	Warringtonfire Australia Pty Ltd	
Address	Unit 2, 409-411 Hammond Road, Dandenong South, VIC 3175	
Phone	T: +61 (0)3 9767 1000	
ABN	81 050 241 524	
Email	info.fire.melbourne@warringtonfire.com	
Authorisation	Prepared by:	Reviewed by:
		
	Tanmay Bhat	Mahmoud Akl